

FINAL INSPECTION REPORT

Under the *Retirement Homes Act, 2010*

Inspection Information	
Date of Inspection: June 11, 2015	Name of Inspector: Rachelle Harber
Inspection Type: Routine Inspection	
Licensee: 1814124 Ontario Inc. / 175-181 Niagara Street, St. Catharines, ON L2R 4M1 (the "Licensee")	
Retirement Home: Niagara Gardens Retirement Manor / 175-181 Niagara Street, St. Catharines, ON L2R 4M1 (the "home")	
Licence Number: S0195	

Purpose of Inspection
The RHRA conducts routine inspections as set out in section 77(3) of the <i>Retirement Homes Act, 2010</i> (the "RHA").

NON-COMPLIANCE
1. The Licensee failed to comply with the RHA, S.O. 2010, c. 11, s. 55; Posting information. The Licensee failed to comply with O. Reg. 166/11, s. 11; Posted information. Specifically, the Licensee failed to comply with the following subsection(s): 55. (2) Every licensee of a retirement home shall ensure that the following information is posted in the home in a conspicuous and easily accessible location and in a manner that complies with the prescribed requirements, if any: 3. An explanation of the measures to be taken in case of fire. 11. (1) For the purposes of paragraph 4 of subsection 55 (2) of the Act, the following information is prescribed as information that must be posted in a retirement home under that subsection: 3. An explanation of the procedures to be followed in the case of an evacuation.
Inspection Finding The Licensee did not post the required information related to fire measures and evacuation.
Outcome Corrective action taken by the Licensee.
2. The Licensee failed to comply with O. Reg. 166/11, s. 24; Emergency plan, general. Specifically, the Licensee failed to comply with the following subsection(s):

24. (5) The licensee shall,

(a) on an annual basis at least, test the emergency plan, including arrangements with community agencies, partner facilities and resources that will be involved in responding to an emergency, related to,

(iii) medical emergencies,

(iv) violent outbursts;

(c) keep a written record of the testing of the emergency plan and planned evacuations and of any changes made to improve the emergency plan.

Inspection Finding

The Licensee did not test the emergency plan related to violent outbursts and medical emergencies. Further, the Licensee did not keep a written record of the testing and the changes made to improve the system.

Outcome

Corrective action taken by the Licensee.

NOTICE

The Final Inspection Report is being provided to the Licensee, the Registrar of the Retirement Homes Regulatory Authority (the "RHRA") and the home's Residents' Council, if any.

Section 55 of the RHA requires that the Final Inspection Report be posted in the home in a conspicuous and easily accessible location. In addition, the Licensee must ensure that copies of every Final Inspection Report from the previous two (2) years are made available in the Home, in an easily accessible location.

The Registrar's copy of the Final Inspection Report, as it appears here, will be included on the RHRA Public Register, available online at <http://rhra.ca/en/register/>

Signature of Inspector 	Date July 13, 2015
---	-----------------------